



Pennsylvania Department of Environmental Protection

2 Public Square
Wilkes-Barre, PA 18711-0790
September 8, 2005

Northeast Regional Office

570-826-2511
Fax 570-820-4907

NOTICE OF VIOLATION

B. Braun Medical, Inc.
1901 Marcon Boulevard
Allentown, PA 18103

Re: Permit/Registration File
Facility Operations Inspection
B. Braun Medical
Facility ID No. 39-37781
Hanover Township, Lehigh County

Dear Sirs:

On August 31, 2005, certified inspector Gregory Dubas conducted a Facility Operations Inspection at the above referenced facility. An inspection report documenting the findings of that inspection was provided to you (or your representative) and the Department.

We have reviewed the report to determine compliance with the Storage Tank and Spill Prevention Act and the applicable technical regulations in 25 Pa. Code Chapter 245. According to the inspector's report, the following violations exist:

- The tank's interstitial monitoring system should be checked at least once per month as per 245.441. The monitoring results are to be kept on file for at least 12 months as per 245.435. Please send this office copies of the monitoring results from August and September 2005.

We request that you submit, by October 15, 2005, documentation that the violations listed above have been corrected. Acceptable documentation may be in one or more of the following forms:

1. Submission of a follow-up inspection report, prepared by a certified inspector, confirming violations have been resolved.
2. Submission of a tank modification report signed by a certified installer showing that your tank system has been brought into compliance. Certified installers will have the required tank modification report form.




3. Proof of purchase and installation, testing, or repair of equipment required to come into compliance.
4. Other suitable documentation.

If you need additional time to bring your tank system into compliance, please contact this office and provide me with a schedule for bringing your facility into compliance. If we do not receive documentation or a compliance schedule from you by the date indicated above, we may schedule a compliance inspection at your facility.

Continued violations that are documented as a result of this follow-up inspection may result in enforcement action, including civil penalties, against you.

If you have any questions pertaining to storage tank system compliance or this letter, please contact me at 570-826-2511.

Sincerely,

A handwritten signature in dark ink, appearing to read "Eric Supey", with a stylized flourish at the end.

Eric Supey
Water Quality Specialist Supervisor
Environmental Cleanup Program